

MINISTRY OF PETROLEUM RESOURCES

DEPARTMENT OF PETROLEUM RESOURCES

7 KOFO ABAYOMI STREET, VICTORIA ISLAND, LAGOS

12650

P.M.B. No: 2790000, 4611777

Telephone:

Website: www.dprnigeria.com



DPR/LA/DS/PDJ /SSL/V.1/77

Ref. No: 20th February, 2012

Date:

The Managing Director,
Wabeco Petroleum Limited,
118 Adeola Odeku street,
Victoria Island,
Lagos.

Dear Sir,

APPROVAL TO CONSTRUCT A PETROLEUM PRODUCT STORAGE DEPOT BESIDE NPA PORT, CALABAR, CROSS RIVERS STATE.

We refer to your application of June 30th, 2011 for approval to construct (ATC) a petroleum products storage tank farm at the above named address and the subsequent site inspection carried out by the representatives of this office.

In view of the satisfactory report therefrom and the consent obtained from other appropriate Government Agencies, **approval** is hereby granted to **WABECO PETROLEUM LIMITED** to commence the construction of following petroleum products storage tanks and other associated ancillaries:

- Storage Tanks
 - Automotive Gas Oil (AGO) 12,700,000 litres [One (1) tank].
 - Automotive Gas Oil (AGO) 2 x 8,800,000 litres [Two (2) tanks]
 - Dual Purpose Kerosene (DPK) 8,800,000 litres [One] (1) tank]
 - Dual Purpose Kerosene (DPK) 630,000 litres [One] (1) tank]
 - Premium Motor Spirit (PMS) 12,700,000 litres [One (1) tank]
 - Premium Motor Spirit (PMS) 2 x 8,800,000 litres [Two (2) tanks]
 - Bitumen 5,560,000 litres [One (1) tank]
 - Bitumen 3,600,000 litres [One (1) tank]
 - Bitumen 2,400,000 litres [One (1) tank]
- Loading Gantry.
- API Separator
- Fire Water Tank
- Truck Holding Bay.

This ATC is granted under the following conditions, that

1. The DPR shall routinely monitor the construction and must be present when integrity tests (leak detection test and hydrotest) and calibration of tanks are to be carried out. It is therefore your responsibility to ensure that the dates for such exercises are brought to the attention of this office.
2. All impact mitigation/monitoring in the Environmental Impact Assessment (E.I.A) report as indicated in the Environmental Management Plan is comprehensively implemented during the construction and operation phases.
3. All petroleum Products dispensing meters and pumps shall be subjected to Factory Acceptance Tests (FAT). It is mandatory to involve the Department during FAT tests prior to shipment.
4. The truck holding bay shall be concreted with cement.
5. At the completion of the project, a detailed operational safety case shall be carried out by a DPR accredited consultant.
6. You are also to avail yourself of regular visits by the Department's inspectors during and after the construction to enable you abide by the Laws and Regulations guiding the establishment of fuel depots/installations.

You are therefore requested to strictly adhere to the above as the issuance of operating license for the facility will be dependent on total compliance.

Yours faithfully,



A.M. Mudei

For: Director, Petroleum Resources.