

Product Certificate Number	20788-1-CER	
Applicant	Fronius Straße 1, 4600, Wels-Thalheim, Austria	
Series	Tauro Eco	
Models	Tauro Eco 50-3-P Tauro Eco 50-3-D Tauro Eco 99-3-P	Tauro Eco 99-3-D Tauro Eco 100-3-P Tauro Eco 100-3-D
Type of generating unit	Three-Phase Solar Inverter	
Technical Data	See page 2 and 3	
Software version	1.13.6-1	
Standard	UNE 206007-1:2013 IN. Requisitos de conexión a la red eléctrica. Parte 1: Inversores para conexión a la red de distribución.	
Having assessed the report numbers: 28120006 003 performed by TÜV Rheinland (Accredited Laboratory No. 1356 L) and 20788-1-TR performed by CERE (Accredited Laboratory No. 5314.01) and based on the requirements of the EN ISO/IEC 17025: 2017. The above-mentioned generating unit complies with the requirements of the: UNE 206007-1:2013 IN. Requisitos de conexión a la red eléctrica. Parte 1: Inversores para conexión a la red de distribución. This certification is according the CERE internal process PET-CERE-09 Rev 30 based on the requirements of the EN ISO/IEC 17065:2012. For this certification process the conformity assessment activities were based on: • Testing of production samples selected by CERE. • Audit of quality system according ISO 9001 with certificate number: 00018945 issued by a certification body accredited according EN ISO/IEC 17021. • Inspection of the manufacturing process.		
Madrid, May 21, 2021. This certificate is valid until May 21, 2024. Miguel Martínez Lavin Certification Manager		

Technical data

Model	Tauro Eco 50-3-P	Tauro Eco 100-3-P
Input data		
Maximum current (A)	87,5	175
Voltage range (V)	580-1000	580-1000
Feed-in start voltage (V)	650	650
Output data		
Nominal power (kW)	50	100
Maximum power (kVA)	50	100
Nominal current (A)	76	152
Grid connection (V)	3~ NPE 400/230 V; 3~ NPE 380/220 V	3~ NPE 400/230 V; 3~ NPE 380/220 V
Frequency (Hz)	50	50
General data		
Dimensions (height x width x depth)	755 x 1109 x 346 mm (without wall mount)	755 x 1109 x 346 mm (without wall mount)
Weight	74 kg	103 kg
Degree of protection	IP 65	IP 65
Protection class	1	1
Ambient temperature range	- 40 to + 65 °C (*)	- 40 to + 65 °C (*)

(*) Optional AC-disconnect mounted inside the inverter: from - 25 to + 65 °C


Model	Tauro Eco 50-3-D	Tauro Eco 100-3-D
Input data		
Maximum current (A)	87,5	175
Voltage range (V)	580-1000	580-1000
Feed-in start voltage (V)	650	650
Output data		
Nominal power (kW)	50	100
Maximum power (kVA)	50	100
Nominal current (A)	76	152
Grid connection (V)	3~ NPE 400/230 V; 3~ NPE 380/220 V	3~ NPE 400/230 V; 3~ NPE 380/220 V
Frequency (Hz)	50	50
General data		
Dimensions (height x width x depth)	755 x 1109 x 346 mm (without wall mount)	755 x 1109 x 346 mm (without wall mount)
Weight	74 kg	103 kg
Degree of protection	IP 65	IP 65
Protection class	1	1
Ambient temperature range	- 40 to + 65 °C (*)	- 40 to + 65 °C (*)

(*) Optional AC-disconnect mounted inside the inverter: from - 25 to + 65 °C

Model	Tauro Eco 99-3-D	Tauro Eco 99-3-D
Input data		
Maximum current (A)	175	175
Voltage range (V)	580-1000	580-1000
Feed-in start voltage (V)	650	650
Output data		
Nominal power (kW)	99	99
Maximum power (kVA)	99	99
Nominal current (A)	152	152
Grid connection (V)	3~ NPE 400/230 V; 3~ NPE 380/220 V	3~ NPE 400/230 V; 3~ NPE 380/220 V
Frequency (Hz)	50	50
General data		
Dimensions (height x width x depth)	755 x 1109 x 346 mm (without wall mount)	755 x 1109 x 346 mm (without wall mount)
Weight	101 kg	101 kg
Degree of protection	IP 65	IP 65
Protection class	1	1
Ambient temperature range	- 40 to + 65 °C (*)	- 40 to + 65 °C (*)

(*) Optional AC-disconnect mounted inside the inverter: from - 25 to + 65 °C

Electrical Diagram of Tauro ECO P



The sample selected to test was representative of the production. The sample was selected in:

Fronius International GmbH
Fronius Strasse 5, 4642, Sattledt, Upper Austria,
Austria

Sample Report Number:

20788-TM

The inspection of manufacturing process was performed in:
On March 29, 2021.

Fronius International GmbH
Fronius Strasse 5, 4642, Sattledt, Upper Austria,
Austria

Inspection Report Number:

20788-21-1-IF

RECORD OF CHANGES

Revision	Modification / Changes	Date
0	Initial version	21/05/2021